

No	Year	Cost Disburs (G, T & D)	Additional Infrastruct. Cost	Energy Generated MWh	Energy Sent-out MWh	Energy Sold MWh	Average Tariff RM/kwh	Average Revenue Million	Var O&M Million	Fixed O&M Million	Fuel Prices \$/Mil.Kcal	Coal Prices \$/Mil.Kcal	T, D & A Var Cost Million	Total Oper.Cost Million	Average Cashflow Million
-6	1994						0.2003								
-5	1995						0.2003								
-4	1996	\$210					0.2003								
-3	1997	\$182					0.2003								
-2	1998	\$911					0.2003								
-1	1999	\$1,094					0.2003								
0	2000	\$729					0.2003								
1	2001	\$729					0.2003								
2	2002			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
3	2003			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
4	2004			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
5	2005			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
6	2006			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
7	2007			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
8	2008			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
9	2009			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
10	2010			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
11	2011			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
12	2012			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
13	2013			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
14	2014			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
15	2015			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
16	2016			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
17	2017			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
18	2018			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
19	2019			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
20	2020			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
21	2021			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
22	2022			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
23	2023			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
24	2024			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
25	2025			6,132,000	5,702,760	5,132,484	0.2003	\$1,028							
<b>NPV</b>		<b>\$1,983</b>	<b>\$444</b>												<b>\$3,843</b>
															<b>\$1,589</b>

Benefit/Cost Ratio = 0.93  
IRR = 10%

## **APPENDIX 1**

## APPENDIX 1

### WIEN AUTOMATIC SYSTEM PLANNING PACKAGE (WASP)

The Wien Automatic System Planning Package (WASP) was developed by the Tennessee Valley Authority (TVA) and the Oak Ridge National Laboratory (ORNL) of the United States of America to meet the needs of the International Atomic Energy Agency (IAEA) "Market Survey for Nuclear Power in developing Countries" conducted by the Agency in the period 1972 - 1973. Based on the experience gained many improvements were made which led to the WASP II version in 1976. later the need to incorporate the study on interconnection of electrical grids led to a joint effort to develop WASP III version.

WASP III was designed to find the economically optimal generation expansion policy for an electric utility system within user specified constraints. It utilises probabilistic estimation of system production costs, unserved energy cost, and reliability and the dynamic method of optimisation for comparing the costs of alternative system expansion policies. The modular structure of WASP III permits the user to monitor intermediate results, avoiding waste of large amounts of computer time due to input data errors.

The computer time requirement to carry out a generation planning study using WASP III depend on:

- (a) the complexity of the system under study
- (b) The number of hydrological conditions considered

- (c) The number of periods into which the year is divided.
- (d) the total number of years considered
- (e) the accuracy required for simulating the system operations
- (f) the total number of configurations generated during the study

WASPIII permits finding the optimal expansion plan for the power generating system over a period of over thirty years, within constraints given by the planner. the optimum is evaluated in terms of minimum discounted total cost.

Each possible sequence of power units added to the system meeting the constraints is evaluated by means of cost function (the objective function) which is composed of:

- Capital investment cost
- Salvage value of investment cost
- Fuel cost
- Fuel inventory cost
- Non-fuel operations and maintenance cost
- Cost of energy not served.

thus

$B_j =$

Where  $B_j$  is the objective function attached to the expansion plan

- ▶  $t$  is the time in years
- ▶  $T$  is the length of the study period

The reliability of the system configuration is evaluated by WASPIII in terms of the Loss-of-Load Probability Index (LOLP). this index is calculated by the code for each period and each condition.

The calculation of the various costs components in the expression is done in WASP in order to account for:

- ▶ Characteristic of the Load forecast
- ▶ Characteristic of thermal and nuclear plant
- ▶ Characteristic of hydroelectric plant
- ▶ Stochastic nature of the hydrology
- ▶ Cost of energy no served.

In WASPIII there are 7 modules to be executed in sequence,. The modules are:

LOADSY	Processes information describing period peaks loads and load duration curves for the power system over the study period.
FIXSYS	processes information describing the existing generation system and any predetermined additions or requirements
VARSYS	processes information describing the various generating plans which are to be considered as candidate for expanding the generating system
CONGEN	calculates all possible year to year combination of expansion candidate additions which satisfy certain input constraint and which in combination with the fixed system can satisfy the loads.

MERSIM considers all configurations put forward by CONGEN and uses probabilistic simulation of system operations to calculate the associated production costs, energy not served and system reliability for each configuration. the module also calculates plants loading orders if desired, and make use of all previously simulated configurations.

DYNPRO determines the optimum expansion plan based on previously derived operating costs along with input information on capital cost, energy not served cost and economic parameters and reliability criteria.


REPROBAT create a report summarising the total or partial results for the optimum or near optimum power system expansion plan and for fixed expansion schedules.

The chart overleaf denotes the flow chart for the processing of data. In order to determine the capacity addition to the TNB system, the research was carried out by first obtaining the base case for the least cost plant addition to the system. The least cost as indicated above will determine from the WASPIII model which has been adopted by TNB.


With the findings conclusions can be drawn on what is the least cost generation development for TNB. The base case is the additional plant required by the country between now to year 2005. This is the least cost option for the country.

However, it may not be the least cost for the utility and the implementation of the actual projects need to be review annualy to assess variation in load demand which will determine a different planning scenario. However this paper will assumed that the base case for plant addition and look at the investment strategy if TNB decides to take up this projects.

# ADDITIONAL ANALYSIS ARE REQUIRED



**Figure 1.1 : Flow Chart of WASP Programme**



## **APPENDIX 2**

## APPENDIX 2

### SCREENING CURVES

The screening curve method is a simplified approach for quick analysis of economic competitiveness. Basically the screening curve separates the technology costs into fixed and variable costs. This is followed by constructing the cost curve for each technology which is a plot of cost (\$/kW-yr) vs capacity factor. The least cost alternative will be determined as a function of utilisation. This approach has numerous limitations and it cannot be used as a substitute for thorough analysis as in WASPIII.

#### Total fixed cost

The total fixed costs are independent of the energy kWh generated by the unit. It can be represented by:

Annualised fixed cost =

Total capital cost x Levelised annual fixed charge rate + Fixed O&M cost

where the levelised annual fixed charge rate = capital recovery factor

#### Total variable cost

The variable cost on the other hand includes costs that are proportional to kWh generated and can be represented as:

Variable cost = Annual average heat rate x Fixed cost + Variable O&M cost

The fuel and operation and maintenance cost should be levelised if real escalation is assumed.

### Total Cost

The total cost will thus be =

Annualised fixed cost + variable cost x capacity factor x 8760 and will produce the chart below.

### Constraints of the Screening curve

The screening curve approach does not allow for many important factors in capacity planning. This will be discussed in turns as follows.


Firstly, the unit availability is not accounted for. Hence the forced outage rate and maintenance frequency are not represented in the curve.


Secondly, it does not include the role of existing plant in the system. therefore the performance of existing units are not fairly treated.

Thirdly, the screening curve is not able to incorporate the dispatching role of the candidate plants. this means the minimum load capability, the spinning reserve contribution and startup cost are not taken into consideration.

Fourthly, the reliability criteria is not imposed or included. As in WASPIII and discussed in the text, reliability criteria is an important input to planning.

Fifthly, dynamic factors such as load growth and economic trends are not considered. therefore the curves are instantaneous information. this also means that the the curve is not able to be used for interpreting long term sequence of the short term results.





## **APPENDIX 3**

Capacity =	2000 M.W.	Efficiency =	50%				
Aux.Cons =	7%	T&D Loss =	10%				
Cap. Cost =	\$2,741 RM/kw	Fix O&M =	35.04 RM/kw/year				
IDC =	23.78%	T&D Cost =	33% of Definite Works				
Total Cost =	\$2,741 Million	Definite Works Disbursement					
Infras.Cost =	\$700 Million	Year-1	Year-2	Year-3	Year-4	Year-5	Total
Disc.Rate =	10%	5%	25%	30%	20%	20%	100%
		\$137	\$685	\$822	\$548	\$548	\$2,741

No	Year	Disburs (G, T & D)	Infrastruct. Cost	Generated MWh	Sent-out MWh	Sold MWh	Tariff kM/kwh	Revenue Million	Oper.Cost Million	Var Cost Million	Average O&M Cost \$/Mil.Kcal	Prices \$/MWh	Cost Million	(\$392) (\$1,261) (\$1,234) (\$729) (\$729)	Cashflow Million
-6	1994	0.2003	0.2003	5,132,484	5,132,484	5,132,484	0.2003	\$1,028	\$35	\$14	\$14	\$14	\$255	\$396	\$632
-5	1995	0.2003	0.2003	5,132,484	5,132,484	5,132,484	0.2003	\$1,028	\$35	\$14	\$14	\$14	\$266	\$408	\$620
-4	1996	0.2003	0.2003	5,132,484	5,132,484	5,132,484	0.2003	\$1,028	\$35	\$14	\$14	\$14	\$278	\$420	\$608
-3	1997	\$210	\$210	5,132,484	5,132,484	5,132,484	0.2003	\$1,028	\$35	\$14	\$14	\$14	\$20.053	\$423	\$607
-2	1998	\$911	\$350	5,132,484	5,132,484	5,132,484	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.181	\$280	\$421
-1	1999	\$1,094	\$140	5,132,484	5,132,484	5,132,484	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.310	\$282	\$423
0	2000	\$729	\$729	5,132,484	5,132,484	5,132,484	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.439	\$284	\$425
1	2001	\$729	6,132,000	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.570	\$285	\$427
2	2002	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	19.184	\$92	\$620
3	2003	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.053	\$92	\$608
4	2004	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.181	\$92	\$607
5	2005	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.310	\$92	\$605
6	2006	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.439	\$92	\$603
7	2007	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.570	\$92	\$601
8	2008	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.701	\$287	\$429
9	2009	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.844	\$289	\$431
10	2010	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	20.988	\$291	\$433
11	2011	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	21.133	\$293	\$435
12	2012	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	21.278	\$295	\$437
13	2013	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	21.425	\$297	\$439
14	2014	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	21.573	\$299	\$441
15	2015	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	21.722	\$301	\$443
16	2016	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	21.872	\$303	\$445
17	2017	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	22.023	\$306	\$447
18	2018	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	22.175	\$308	\$449
19	2019	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	22.328	\$310	\$451
20	2020	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	22.482	\$312	\$453
21	2021	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	22.637	\$314	\$455
22	2022	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	22.794	\$316	\$458
23	2023	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	22.951	\$318	\$460
24	2024	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	23.109	\$321	\$462
25	2025	6,132,000	5,702,760	5,702,760	5,702,760	5,702,760	0.2003	\$1,028	\$35	\$14	\$14	\$14	23.269	\$323	\$464
															\$2,189
															\$5,267

Benefit/Cost Ratio = 1.14  
IRR = 10%

Capacity =	1000 MW	Efficiency =	58%
Aux.Cons =	7%	T&D Loss =	10%
Cap. Cost =	\$2,741 RM/kw	Fix O&M =	35.04 RM/kw/year
IDC =	23.78%	T&D Cost =	33% of Definite Works
Total Cost =	\$2,741 Million	Definite Works Disbursement	
Infras.Cost =	\$700 Million	Year-1	Year-2
Disc.Rate =	10%	5%	25%
		\$137	\$685
		\$822	\$685
		\$548	\$548
			\$2,741

$$\text{Benefit/Cost Ratio} = \frac{1.31}{12\%} =$$

Capacity =	1000 MW	Efficiency =	2,263 kcal/kwh				
Aux.Cons =	7%	T&D Loss =	38%				
Cap. Cost =	\$2,741 RM/kw	Fix O&M =	10%				
IDC =	23.78%	T&D Cost =	35.04 RM/kw/year				
Total Cost =	\$2,741 Million	Definite Works Disbursement	Total				
Infras.Cost =	\$700 Million	Year-1	Year-2	Year-3	Year-4	Year-5	Total
Disc.Rate =	13%	5%	25%	30%	20%	20%	100%
		\$137	\$685	\$822	\$548	\$548	\$2,741

## **APPENDICES**